

ICC-ES Evaluation Report**ESR-3263**

Reissued May 2014

This report is subject to renewal June 1, 2015.www.icc-es.org | (800) 423-6587 | (562) 699-0543

A Subsidiary of the International Code Council®

**DIVISION: 07 00 00—THERMAL AND MOISTURE
PROTECTION****Section: 07 21 00—Thermal Insulation****Section: 07 84 16—Annular Space Protection****REPORT HOLDER:****POWERS FASTENERS, INC.
701 EAST JOPPA ROAD
TOWSON, MARYLAND 21286
www.powers.comengineering@powers.com****EVALUATION SUBJECT:****TRIGGER FOAM PRO FIRE BLOCK, TRIGGER FOAM
PRO WINDOW AND DOOR, TRIGGER FOAM PRO ALL
SEASON FOAM SEALANTS****1.0 EVALUATION SCOPE****Compliance with the following codes:**

- 2012, 2009 and 2006 *International Building Code*® (IBC)
- 2012, 2009 and 2006 *International Residential Code*® (IRC)

Properties evaluated:

- Surface-burning characteristics
- Annular space protection

2.0 USES

Trigger Foam Pro Fire Block, Trigger Foam Pro Window and Door and Trigger Foam Pro All Season are foam sealants used to fill cracks and voids in construction and the annular space created by the penetration of wood fireblocking by pipes and conduits. The sealants are recognized for use as alternatives to the methods prescribed by the code for maintaining the integrity of penetrations of fireblocking.

3.0 DESCRIPTION

Trigger Foam Pro Fire Block, Trigger Foam Pro Window and Door and Trigger Foam Pro All Season are single-component polyurethane foam plastic sealants that expand to take the shape of cracks and voids. The sealants have a flame-spread index of less than 25 and a smoke-developed index of less than 450 when tested in accordance with ASTM E84. The sealants are packaged in an aerosol delivery configuration. The sealants have been tested in accordance with ASTM E814 (modified) to establish that the integrity of the fireblocking is maintained when the fireblocking is penetrated.

4.0 DESIGN AND INSTALLATION

Installation of the sealant must comply with this report and the manufacturer's published installation instructions. The manufacturer's published installation instructions are to be available at the jobsite at all times during installation.

The sealants must be installed to completely fill the annular space around the penetrations for the full depth of the plate that has been penetrated. Use of the foam to fill annular space or cracks must observe the following limitations:

- a. The maximum width of exposed sealant or the annular space of penetrations to be sealed is not to exceed 1¹¹/₃₂ inches (34 mm), and the nominal foam thickness must range from 1¹/₂ inches to 3 inches.
- b. The maximum area of exposed sealant must not exceed 18 square inches per square foot (1247 cm²/m²) of wall area.

5.0 CONDITIONS OF USE

The Trigger Foam Pro Fire Block, Trigger Foam Pro Window and Door and Trigger Foam Pro All Season sealants described in this report comply with, or are suitable alternatives to what is specified in, those codes listed in Section 1.0 of this report, subject to the following conditions:

- 5.1** Materials and methods of installation must comply with this report and the manufacturer's published installation instructions. In the event of a conflict between the manufacturer's published installation instructions and this report, this report governs.
- 5.2** The sealants must not be used in applications where exposed to sunlight or weather.
- 5.3** The sealants must be separated from the interior space by an approved 15-minute thermal barrier complying with the requirements of the applicable code.
- 5.4** Use of the sealants is limited to Type V-B construction under the IBC and to non-fire-resistant-rated construction under the IRC.
- 5.5** Trigger Foam Pro Fire Block, Trigger Foam Pro Window and Door and Trigger Foam Pro All Season sealants are manufactured in Srpenica, Slovenia, under a quality control program with inspections by ICC-ES.

6.0 EVIDENCE SUBMITTED

- 6.1** Manufacturer's product labels with installation instructions.

6.3 Report containing results of comparative testing performed in accordance with a modified version of ASTM E814.

6.4 Quality documentation.

sealants described in this report are identified by a label bearing the Powers Fasteners Inc. name, the product type, the name of the inspection agency and the evaluation report number (ICC-ES ESR-3263).

7.0 IDENTIFICATION

The Trigger Foam Pro Fire Block, Trigger Foam Pro Window and Door and Trigger Foam Pro All Season